Report Date: 9/14/2022 Report Time: 4:06 PM EDT

Region II Hotline Log Entry Information

Data ID: 2303770

Date Of Report: 2/11/2018 NRC #: 1204136 ERNS#: State #:

Material Type: Oil Receiver: Hriczko

Material / Amount: OIL, MISC: MINERAL (500 GALLON(S));

Location: Street:

City: BROOKLYN

County: KINGS(BROOKLYN)

State: NY Longitude:

Source of Pollution: CONSOLIDATED EDISON COMPANY OF NEW YORK

Water Body:

State Or EPA Responded: RP Investigating

Initial EPA Action: Will follow up. (See Action Report)

Status: 2 - Closed

URL:

Associated Action Reports

DataID: 1130076

Date: 2/13/2018 Time: 10:41 Duty Officer/Responder Name: Hriczko NRC Report #: 1204136 Hotline Log DataID: 2303770

Action Information

Description: Contacted Duty officer for Con Ed for an update on the incident. The spill was found in Brooklyn and several gaskets were

blown out. The gaskets were repaired and they are in the process of cleaning up the spill. The updated quantity is 675

gallons, but there were no impacts to water.

Follup-Up:

Person Contacted

Name: David Duke

Organization: Consolidated Edison Company of NY

Phone #: 212-580-8383

NRC Spill Report

NATIONAL RESPONSE CENTER 1-800-424-8802 ***GOVERNMENT USE ONLY***GOVERNMENT USE ONLY***

Information released to a third party shall comply with any

applicable federal and/or state Freedom of Information and Privacy Laws

Incident Report # 1204136

INCIDENT DESCRIPTION

*Report taken by: CIV KEVIN WILLIAMS at 23:29 on 11-FEB-18

Incident Type: FIXED

Incident Cause: EQUIPMENT FAILURE

Affected Area:

Incident was discovered on 11-FEB-18 at 23:07 local incident time.

Affected Medium: LAND UNDERGROUND

REPORTING PARTY

Name: DAVID DUKE

Organization: CONSOLIDATED EDISON COMPANY OF NEW YORK

31ST ST AND 20TH AVE Address:

ASTORIA, NY 11105

PRIMARY Phone: (212)5808383

Type of Organization: PUBLIC UTILITY

SUSPECTED RESPONSIBLE PARTY

DAVID DUKE Name:

Organization: CONSOLIDATED EDISON COMPANY OF NEW YORK

31ST ST AND 20TH AVE Address: ASTORIA, NY 11105

PRIMARY Phone: (212)5808383

Type of Organization: PUBLIC UTILITY

INCIDENT LOCATION

FARRAGUT SUBSTATION County: KINGS (BROOKLYN)

89 JOHNS STREET FEEDER 61

City: BROOKLYN State: NY

RELEASED MATERIAL(S)

CHRIS Code: OMN Official Material Name: OIL, MISC: MINERAL

Also Known As:

Qty Released: 500 GALLON(S) Qty in Water: 0 UNKNOWN AMOUNT

DESCRIPTION OF INCIDENT

CALLER STATED DUE TO A ELECTRICAL FEEDER FAULT THERE WAS A SPILL OF DI-ELECTRIC FLUID (NON-PCB) UNDERGROUND. CALLER STATED THE SPILL IS BETWEEN BROOKLYN AND

THE FEEDER LENGTH IS SEVEN MILES LONG.

INCIDENT DETAILS

Package: N/A Building ID:

Type of Fixed Object: OTHER Power Generating Facility: NO

Generating Capacity:

Type of Fuel:

NPDES:

NPDES Compliance: UNKNOWN

IMPACT

Fire Extinguished: UNKNOWN Fire Involved: NO

INJURIES: NO Hospitalized: Empl/Crew: Passenger: FATALITIES: NO Empl/Crew: Passenger: Occupant:

EVACUATIONS: NO Who Evacuated: Radius/Area:

Damages: NO

> Hours Direction of

Description of Closure Closed Closure Closure Type

Air: N

Road: N Major Artery: N

Waterway:

Track:

Passengers Transferred: NO Environmental Impact: UNKNOWN

Media Interest: UNKNOWN Community Impact due to Material:

REMEDIAL ACTIONS

INVESTIGATION UNDERWAY Release Secured: NO

Release Rate:

Estimated Release Duration:

WEATHER

ADDITIONAL AGENCIES NOTIFIED

Federal: State/Local:

State/Local On Scene: State Agency Number:

NOTIFICATIONS BY NRC

CENTERS FOR DISEASE CONTROL (GRASP)

11-FEB-18 23:36 (770)4887100

DHS DEFENSE THREAT REDUCTION AGENCY (CHEMICAL AND BIOLOGICAL TECHNOLOGIES DEPARTMENT)

23:36 (703)7673477 11-FEB-18

DHS INFRSTR SECURITY COMPLIANCE DIV (REGION 2)

11-FEB-18 23:36 (202) 4655909

DOT CRISIS MANAGEMENT CENTER (MAIN OFFICE)

23:36 (202)3661863 11-FEB-18

U.S. EPA II (MAIN OFFICE)

11-FEB-18 23:42 (732)3214370 HRTCZKO

NATIONAL INFRASTRUCTURE COORD CTR (MAIN OFFICE)

11-FEB-18 23:36 (202)2829201

NJ OFC HMLND SECURITY & PREPAREDNES (COMMAND CENTER)

(609) 9636817 11-FEB-18 23:36

NJ STATE POLICE (MARINE SERVICES BUREAU)

11-FEB-18 23:36 (609)9636900

NOAA RPTS FOR NY (MAIN OFFICE)

11-FEB-18 23:36 (206) 5264911

NY STATE DEC SPILL HOTLINE (MAIN OFFICE)

11-FEB-18 23:36 (518) 4577362

USCG DISTRICT 1 (COMMAND CENTER) 11-FEB-18 23:36 (617)2238555

ADDITIONAL INFORMATION

CALLER STATED ADDITIONAL NOTIFICATIONS WILL BE MADE.

*** END INCIDENT REPORT # 1204136 ***

Report any problems by calling 1-800-424-8802

PLEASE VISIT OUR WEB SITE AT http://www.nrc.uscg.mil